

## Prep/Scale® TFF Cartridge

Catalogue Number: CDUFO06LT

Lot Number: C9HN10177

Membrane Type: PLTK

Membrane Area: 6 ft<sup>2</sup>

### Good Manufacturing Practices

This product was manufactured in a Millipore facility which meets or exceeds FDA Device Good Manufacturing Practice standards.

### ISO 9000 Quality Standard

This product was manufactured in a Millipore facility whose Quality Management System is approved by an accredited registering body to the appropriate ISO 9000 Quality Systems Standard.

### Materials

Membrane: Regenerated Cellulose

Screens: Polyethylene, Polypropylene

Central tube and housing: Polysulfone

Adhesive: Urethane

Toxicity: All parts in the fluid path were tested and meet the criteria for the USP Class VI Biological Test for Plastics.

### 100% Integrity Tested in Manufacturing

Each unit must pass the Millipore Integrity Test based on air flow through the fully-wetted membranes of the filter.

Millipore and Prep/Scale are registered trademarks of Millipore Corporation.  
P35694 Rev E 06/09

### Quality Assurance Lot Release Criteria

Every unit was tested by Manufacturing and released by Quality Assurance to the following specifications:

#### Integrity

Each unit exhibited air flow through fully-wetted membranes less than or equal to 144 cc/min at 10 psig (0.7 bar) inlet pressure.

#### Housing Integrity

Each unit met a housing leakage less than 10 cc/min following pressurization to 80 psig (5.5 bar).

#### Pressure Drop

Each module exhibited a maximum pressure drop of 8 psig (0.55 bar) at 1.1 - 1.6 gpm (4.4-6.2 L/min) average cross flow of clean water at an inlet feed pressure of 40 psi (2.8 bar).

### Quality Assurance Audit Criteria

This product was designed and manufactured to meet the following specifications. Performance is confirmed by testing on an audit basis.

#### USP Oxidizable Substances

Effluent was negative after an RO water flush.

#### Gravimetric Extractables

The extractables level was equal to or less than 1500 mg per m<sup>2</sup> after an RO water flush.

#### Hydraulic Stress

Samples were tested and found to have a burst pressure of greater than 3X the maximum operating pressure of 80 psig (5.5 bar).



Peter Eichert

BioPharmaceutical Quality Manager